

DISPATCH **CONFIDENTIAL**

CLASSIFICATION

PROCESSING ACTION

TO	Chief of Real Estate and Construction, OL	MARKED FOR INDEXING
INFO.		NO INDEXING REQUIRED
FROM	<i>all</i>	ONLY QUALIFIED DESK CAN JUDGE INDEXING
SUB		MICROFILM

Forwarding of Attachment I

ACTION REQUIRED - REFERENCES

Reference:

Re ref A paragraph 3 attachment I lists the electrical loads

which should have been forwarded as attachment

C to the report titled "Design Considerations of the Power

System.

R E C D

C

DC

EX

C/RE

RO

17 May 1968

Attachment as stated

Distribution:
0 & 1 C/RE CD

action → 3
5
8 JUN
RECOR
OL REG

25X1A

CROSS REFERENCE TO

DISPATCH SYMBOL AND NUMBER

DATE

20 MAY 1968

CLASSIFICATION

WOS FILE NUMBER

STAT

Approved For Release 2002/11/20 : CIA-RDP78-06505A000600130001-6

Next 1 Page(s) In Document Exempt

Approved For Release 2002/11/20 : CIA-RDP78-06505A000600130001-6

BLDG	AIR CONDITIONER (KW)	LIGHTS	RECPT & MISC	CONNECTED LOAD	AVERAGE DEMAND	REMARKS
48		.4	.1	.5	.5	
50		1	.4	1.4	1	
51		2.7	.7	3.4	2	
52		1	.7	1.7	1	
53		1	.7	1.7	1	
55		.6	.5	1.1	.8	
64-65-66		2		2	2	Estimated
54		.6	.5	1.1	.8	
Bldg Adjacent to #56		1		1	1	
56		8.6		8.6	5	
58		2	1	3	3	
59	3.2	2.7	.7	6.6	5	
60		3	.5	3.5	2	
68&69		3	2	5	3	
41		1.4		1.4	1	
43		1	2.6	3.6	3	
Misc Flood Lights		1		1	1	
44		2		2	1.5	
45		2	.3	2.3	1.5	

STAT

Approved For Release 2002/11/20 : CIA-RDP78-06505A000600130001-6

Approved For Release 2002/11/20 : CIA-RDP78-06505A000600130001-6